## WASTEWATER DEPARTMENT WORK REPORT

Sept 16th, 2021 – Oct 5th, 2021

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- Training of OIT (ongoing)
- UFPOs
- Vouchers done
- Sludge removal
- Take delivery of polymer
- Asset management training 9/20 and 21<sup>st</sup>
- Replace lamp-hole between on 5<sup>th</sup> St.
- DMR and Ops report completed for August and submitted to DEC and EPA
- Attend NYWEA conference 9/24 in Dansville
- Flush Maddison from Steuben St
- Sewer complaint 9/25 from Maddison, flush again, main clear homeowner problem
- Flush sewer 2<sup>nd</sup> and 4<sup>th</sup> grease build up restaurants inspected.
- Call Cummins, could not reset generator fault on Watkins station
- Flyght working on telemetry for outlying stations, onsite
- Receive 2200 gal alum delivery (phosphorous removal chemical)
- Clean effluent pit
- Conference call with Fluidyne and LDG
- Training on gate operation, all work completed on programming, licensing etc.
- Contact CUES over camera replacement (ongoing)

Regards Terry A Wilcox