

WASTEWATER DEPARTMENT  
WORK REPORT

Dec 7th, 2021 – Dec 21st, 2021

- Operation and maintenance of WW facility
- Monthly JPC meetings
- Daily and weekly samples
- Daily lab testing
- DMR and OPS report completed and submitted November
- Training of OIT (ongoing)
- UFPOs numerous for tree planting
- Vouchers done
- Sludge removal
- Draining of SBR and SAM 3
- Power bumps in plant high winds week of 12/7
- Calls from O Connal plumbing and heating old VFW building lateral install
- Replace pump 2 at Suite Coat lift station
- Req submitted for replacement pumps at Watkins Brewery, and Salt Point Rd lift stations
- Flyght in plant lift station telemetry issues
- Req done for UPS install on BDP press, getting locked out after power bumps
- Polymer order placed, delivered and unloaded
- Start 2022 spreadsheets
- Start building shelving units for storage (ongoing)
- Meet with Cues and Aires (replacement camera unit)

Regards

Terry A Wilcox