

WATER DEPARTMENT  
DAILY WORK REPORT

September 17 – September 30, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank, retired valve at Fifth and Magee, cut and capped east end of 4" main on 400 block Fifth St. Had valve removed and new one installed Magee St. near Sixth St. Installed new flow meter on effluent line leaving water plant. Repaired drip in chlorine injection line. Discovered small leak on North Monroe St. Did some hydrant flushing for MRB Group. Fencing at new water tank is complete. Finished lead and copper report and OEL reports.