

WATER DEPARTMENT
DAILY WORK REPORT

October 6 – October 19, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Received 2 quotes for fencing around water facility. Drew monthly bac-t samples. All samples good. Received piece from Sparling Instruments to repair flow meter at Pressure Station. Repaired small leak on Ninth St. by replacing 8.5 ft section. Disruption was minimal. The four inch water main on this street in poor condition and should be considered for replacement. New water tank at state park has been pumping water through a meter previously unknown to department has now been identified and all information taken including 1,116,000 gallons of "lost" water. We believe there may be other "lost" water. Looking into. Pressure valve replacement by same manufacturer extremely expensive. 2 rebuild kits may work for us in short term, still looking at other options and prices. Discussed a gate and fence repair at the top of Second St. with Terry.