

WASTEWATER DEPARTMENT  
WORK REPORT

Sept 13th – Oct 1st, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. Replace batteries on plant generator and repair fuel tank. Quotes gathered for tree cutting on Magee St. Grievance meeting for personnel issue. Mark all aprons and sidewalks on Magee St with LDG for upcoming paving project. Empty and service North Clarifier for winter. Complete Ops report and DMR report and submit to EPA and DEC. Switch chlorine contact tanks. Numerous UFPOs Magee St. Reset pumps at Salt Point road lift station. Chemical orders placed. Sewer blockage 206 Porter St, homeowner issue.

Regards  
Terry Wilcox