

WASTEWATER DEPARTMENT  
WORK REPORT

Oct 15th – Nov 5th, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. Ops report and DMR submitted to DEC and EPA for month of September. Switch CL contact chambers. To Maddison to get a count on risers for raising manholes for Street Dept paving. Clean CL17s. Maintenance done on plant heaters. Chemical deliveries. Paving on Magee Street, completed Monday Oct 21<sup>st</sup>. Clean DO probes. Onsite for directional bore. Print of OIT applications and give list of candidates for interviewing. Flushing of gravity line to plant from Porter St. full of mud. Attempt to flush broken gravity for Vacri (twice) along railway in front of plant. Assist elect. Dept. in flushing conduit by Dunkin Donuts. Attend ribbon cutting for 14<sup>th</sup> St.

Regards  
Terry Wilcox