

WASTEWATER DEPARTMENT
WORK REPORT

Sept 3rd – Sept 13th, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. Re install new 75 HP motor for digesters. Service both primary clarifiers and take west primary offline for winter. Flush 100 block of 7th Street. Complaint from homeowner on 1000 Magee St from flushing, inspect. Received numerous complaints from resident on Magee St. (throughout whole project). Change CL17 sample pump in mixing chamber. Bypass pumping done for gravity repairs Magee St from 7th St to 9th St. Parts pick up for Magee St. Dye testing on Division St. Work with Vacri on identifying trees that need to be removed for paving project. Replace batteries on back-up generator at the plant (one blew apart).

Regards
Terry Wilcox