

WATER DEPARTMENT
DAILY WORK REPORT

January 8, 2019 – January 20, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Another round of renovations began at water plant, pump stations. New UCMR4 sampling begins with first of four quarterly draws. High level pump station pump #1 replaced and piping redone. Now in service. Tested new pump, now primary H-L pump. Hydrant by laundromat opened to check its operation, leaks by a little will look into further. Received chemical delivery. Worked on budget. Started working on annual water quality report.