

WATER DEPARTMENT  
DAILY WORK REPORT

July 15 – August 5, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Water main to new tank partly finished. Began process of disinfection of pipe and tank. Tank and pipes tested and declared West Second St. section still being worked on. Electrical work continues at plant. Water was briefly stopped at Glen Valley Apartments to hook in new tank main. This caused a boil water notice to G.V. apts. Drew samples, all good, B.W. lifted. Time still being spent in Dix (repairs). Generators installed and working at Dix pump stations. Now using new Padua tank and old tank. Nascar event went smoothly for water department. 2.2 million gallons treated during 4-day event. Four-hour plant checks were done during each day.