

WATER DEPARTMENT
DAILY WORK REPORT

August 20 – September 3, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Ordered chemicals, did some hydrant flushing on S. Jackson St. for rusty water. Had meeting on Magee St. and additional work. Street Department cleared out creek by Steuben St. tank to stop over flowing. Looked for valves near Magee St. and woods south of Orchard St. Drew lead and copper samples. Aqua Logic came and did some work. Looked for and tested valves on and around Magee St. Blowers at plant malfunctioned, called Bouille Electric to trouble shoot, found loose connection and fixed.