

WATER DEPARTMENT
DAILY WORK REPORT

October 1 – October 14, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank, received bottles and drew PFOS/PFOA samples, went to training in Horseheads, found drip in pressure station 10/2, ordered replacement pipe. Drip turned into leak 10/6, temporary repair made. Had raw water intake screen cleaned. Drew monthly samples. Repaired hydrant flow meter. Added riser to hydrant guard valve on Magee St. Received chemical delivery. Went to prevailing wage meeting. Looked into water problem at 215 Reading Rd. Traded e-mails with MRB Group, discussed abandonment of old padua tank with Vacri.